



NATIONAL EDUCATION SOCIETY (R)

Off.: 08182-276707
Fax: 08182-222450

Jawaharlal Nehru National College of Engineering

(Affiliated to Visvesvaraya Technological University & Recognised by AICTE & Accredited by NBA)

DEPARTMENT OF CIVIL ENGINEERING

Ref. No.: JNNCE/CE *187* /2014-15

SHIMOGA - 577 204
KARNATAKA STATE

To,

Chiguru Education Trust, Bhadravathi
(Narahari R Borkar, Ravindra Nagar
4th cross, Shimoga

Sir

Sub: Testing of SBC of soil samples for the construction of G+3 School building at
Bhadravati By pass road, Shimoga dist

Ref: Your letter No: CET/BDVT/SB/SBC/2014-15/01-04-2015

As per their request soil sampling has been made for the proposed construction of G+3 School building at Bhadravati By pass road, Shimoga dist. Surface soil is dark brown colour extended upto 0.30m to 0.40m. Further well graded sandy soil extended 0.60m to 0.80 m. Subsequently whitish colour coarse grained soil met with and extended upto, sampling depth. Water is seen in all the open pits. The details of laboratory analysis are as follows.

Particulars	Pit-1	Pit-2	Pit-3	Pit-4	Pit-5
Bulk density kN/m^3	19.75	20.01	19.77	18.91	20.42
Dry density kN/m^3	16.91	16.71	17.82	16.95	17.05
Depth of sampling m	1.80	1.80	1.80	1.80	1.80
S B C kN/m^2	190.00	185.00	200.00	190.00	198.00

[Signature]
Lab instructor

[Signature]
Staff in charge

[Signature]
Coordinator

[Signature]
Principal

BUILDING SAFETY CERTIFICATE

No. 1665

Dated : 21/01/2020

Certificate that the **SPOORTI INTERNATIONAL SCHOOL**, Visweshwarya Nagar, Near Bypass Road, Bhadravathi comprised of Ground floor and First floors owned by **SPOORTI INTERNATIONAL SCHOOL**, have complied with the building bye laws in accordance with rule of State/UT, and incorporate the provisions of building safety as specified in National Building Code 2005, 2016 and as amended thereafter and has been verified by the concerned officer on 21-01-2020 in the presence of Secretary, Sri Mohan H. P Visweshwarya Nagar, Near Bypass Road, Bhadravathi and that the said above building is safe and fit for running School with effect from 26-05-2016 for a period of 40 years in accordance with rules

Issued on 21-01-2020 at Bhadravathi by Assistant Executive Engineer

Signature with seal

ಸಹಾಯಕ ಕಾರ್ಯನಿರ್ವಾಹಕ ಇಂಜಿನಿಯರ್

Authority : ಸಂ. 3 ಭದ್ರಾವತಿ ಉಪನಿಭಾಗ
ಕರ್ನಾಟಕ ರಸ್ತೆ, ಭದ್ರಾವತಿ.

Designation : _____

To

SPOORTI INTERNATIONAL SCHOOL,
Visweshwarya Nagar,
Near Bypass Road,
Bhadravathi